Automation Control Protocol



Last modified on March 2, 2017

Table of Contents

Establishing and Using a Connection	3
Automation Control Commands Reference	3
Example	3

The SOS automation interface (also known as the show floor control protocol) is available via a TCP connection to the main SOS system. This interface allows extensive control of the operation of SOS by an external computer, as a coordinated part of a larger exhibit. For example, SOS could be synchronized with films or Powerpoint display programs, controlled by an interactive kiosk, or run on an automatic daily schedule of timed presentations.

Establishing and Using a Connection

To use the SOS Automation Interface, establish a TCP connection to socket 2468 on the main SOS host. The SOS Automation Interface uses an ASCII line-oriented protocol. Each command is a single line of text. Every command will result in a response from the SOS system. After establishing the TCP connection, it may be kept open and used for multiple commands, but the very first command must be the word "enable". This is neither an actionable command nor a real password, but is used as a simple-minded way to avoid dealing with random socket probes and scans.

Command responses are also ASCII and line-oriented. The error response is the letter "E" (for Error) followed by a two-digit error code, all on a single line. Future error codes may be more precise, but at present this is almost always the string "E04".

The default successful command response is the letter "R" (for Ready) on a single line. This indicates successful completion of commands that have no return value (e.g. stop). It also indicates success and the end of the list for commands that return more than one line (e.g. get_clip_info *). Commands that always return a single line of information (e.g. get_frame_count) return only that line of information in the successful case, and don't return an "R" character.

Automation Control Commands Reference

The individual commands of the SOS automation control protocol are described in the following sections:

- Automation Commands Reference Version 5.0.0+
- Automation Commands Reference Version 4.3.0+
- Automation Commands Reference Version 4.0.1+

Example

Here is a trivial example of the automation interface, using telnet to establish an interactive session. Commands typed by the user are shown in **bold**.

```
[sos@pt-nc ~]$ telnet localhost 2468
Trying 127.0.0.1...
Connected to localhost.
Escape character is '^]'.
enable
R
help

Available Commands:
help
shutdown
open_playlist playlist_file
play [clip_number]
stop
next_clip
```

```
prev_clip
        pause
       step n_frames
       skip frame_number
       set_frame_rate fps [first_dwell_ms last_dwell_ms]
       set_tilt x [y] [z]
       get_animating
       get_frame_count
       get frame number
        get_clip_count
       get_clip_number
       get_clip_info [clip_number|*]
       get frame rates
       get_tilt
       identify [on|off]
        alignment [alignment_command]
       texture filename
       load filename|dirname
       set_auto_presentation_mode [0|1]
       pic_mute
        rotate_projectors
       set_simage [0|1]
        exit
R
get_clip_info *
1 Hot Topo (Wild Fires)
2 2004 Hurricane Season
3 NCDC SST Anomaly (1980 - 1999)
4 GFDL CO2 x 4
5 X-Ray Sun
6 Red Mars (23 degree tilt)
7 Paleo Geographic
8 BlueMarble (23 degree tilt)
9 ACARS track 24hr time seq (45 degree) 07-21-04
10 Indian Tsunami V3
11 NOAA Logo over EC
R
get_clip_number
10
get_frame_count
420
get_frame_number
243
get_frame_number
284
exit
Connection closed by foreign host.
[sos@pt-nc ~]$
```

Support: Automation Control Protocol		